


**PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION**  
**CERTIFICATE.**

No. \_\_\_\_\_

Date : 08/07/2024

It is certified that an inspection team headed by AEN PHED (Name of Officers with designation) from Hannamangarh Junction (Name of Department/Office) inspected the DAV Centenary Public School (Name & Address of the School) on 03/07/2024 and found that the DAV Centenary Public School, Hannamangarh Junction (Name of school) has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/State/U.T Govt.

The above valid for a period of 01 Year.

Signature with Seal :   
 Name : जन स्वा०अभि० विभाग  
 Designation : उपखण्ड हनुमानगढ़ नक्सान  
कोड नं. 17587

To

DAV Centenary Public School  
Near PHED, SNR Abokar Bypass Road  
Hannamangarh Junction

(Name &amp; Address of the Institution)





# Public Health Engineering Department

District Laboratory, Hanumangarh

## REPORT OF THE CHEMICAL EXAMINATION OF WATER

No. / JC / Lab / HMH / C.R / 2024 -2025 350 Dated 03/07/2024

To,

HANUMANGARH

The DAV CENTENARY  
PUBLIC SCHOOL  
HANUMANGARH Jh

Distt. ....


Tehsil HMH

Reference : Your Letter No. .... "qy"

Date of Receipt 28/6/24

1.	Lab Sample No.	315				
2.	Name of Sample	Tap				
3.	Name of Village & Code No.	DAV CENTENARY PUBLIC SCHOOL				
4.	Date of Collection	28/6/24				
5.	Collected By	gms				
6.	Date of Report					
B. EXAMINATION REPORT		Note : All Result Except PH are in mg./Litter				
1.	PH	7.85				
2.	Turbidity	01				
3.	Odour	unobj				
4.	Colour	01				
5.	Alkalinity Phenolphthalein (CaCo3)	211				
6.	Alkalinity Methyle Orange (CaCo3)	100				
7.	Total Hardness (CaCo3)	110				
8.	Calcium Hardness	60				
9.	Megnesium Hardness	50				
10.	Chlorides (as Cl)	20				
11.	Sulphate (as SO4)					
12.	Nitrates (as NO3)	02				
13.	Total Dissolved Solides (T.D.S.)	300				
14.	Flourides	0.23				

Remark :

  
JUNIOR CHEMIST  
PHED LAB, HANUMANGARH

No. / JC / Lab / HMH / C.R / 20 -20  
Copy submitted to :-

Dated 03/07/2024

JUNIOR CHEMIST





# Public Health Engineering Department

District Laboratory, Hanumangarh

## BACTERIOLOGICAL EXAMINATION REPORT

No. / JC / Lab / HMH / BR / 2024/2025

351

Dated 03/07/2024

To,

The DAV CENTENARY

HANUMANGARH

PUBLIC SCHOOL

Distt. ....

HANUMANGARH JN

Tehsil Hanu

Reference : Your Letter No. ....

Date of Receipt 28/6/24

Sample Collected by Jha

Sample No.	Date & Time of Collection	Date of Examination	Residual Chlorine in PPM	Particulars of Sample	Coliform organism MPN Per 100 ml
906	28/6/24 10:00 AM	28/6/24	NH	Tap DAV CENTENARY Public School Hanu	24

Remark :

JUNIOR CHEMIST  
PHED LAB, HANUMANGARH

No. / JC / Lab / HMH / BR / 20 -20

Copy submitted to :-

Dated 03/07/2024

JUNIOR CHEMIST



**CHIEF MEDICAL AND HEALTH OFFICE, HANUMANGARH (Raj.)**

S.No:- 4686

Date:- 4/4/2025

**Subject:-Regarding Certificate of Sanitary Condition.**

Name of School:- **DAV CENTENARY PUBLIC SCHOOL**

**ABOHAR-SGNR BY-PASS ROAD, HANUMANGARH JN.**

Total No. of Students :- **300**

Total No. of Class room:-**16**

Biology Lab + Chemistry Lab+ Physics Lab (Composite Lab):- **04 Fan**

Computer Lab:- **02 AC + 06 Fan**

No. of fans in each Class room:- **64**

No. Urinals (Boys) :-**12**


No. of Urinals (Girls) :-**12**

No. of Urinals (Staff) :-**05**


Exhaust fans in Urinals(Y/N) :-**Yes**

Water Supply:-**PHED**

**During inspection of the above institution sanitary condition found satisfactory.**

  
(Rafik Mohammed)  
Food Safety Officer  
Hanumangarh

**Signature valid**

 (Dr. Navneet Sharma)  
Designation: Chief Medical And  
Health Officer  
Date: 2025.04.04 17:48:59 IST  
Reason: Approved